



ठाणे महानगरपालिका  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE  
प्रदूषण नियंत्रण कक्ष  
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,  
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6<sup>th</sup> November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane, Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 3737  
Sample No. : P1685

Date : 20 March 2024

**Water Analysis Report**

TMC/PCC/20/RO

Name Of the Organisation : M/S New Horizon Scholars School

Address : Vasant Lawns, Near jupiter Hospital, Thane (W)

E\_mail ID : nhssvl.store@newhorizonsms.com

Date of receiving Sample : 19 March 2024

Sample Collected by : Akash Jagtap

Type of Water Sample : Storage Drinking (4th sample)

Parameters	Results	Limits as per IS 10500
pH	7.30	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	24.0	250 mg/L
Total Hardness	50.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

20-Mar-24

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

20-Mar-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (4th sample) Water sample received to our Vakratunda Laboratory on 19/3/2024. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/LOS/PLC/00006/23-24 dated 12.06.2023

This Report has been Signature Digitally.

Principal

New Horizon Scholars School  
Vasant Lawns, Thane