



ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.
THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 878

Date - 15/02/2024

FIRE SAFETY CERTIFICATE

Certified that the New Horizon Scholars School (name of the building or Premises) at Vasant Lawns, Subhash Nagar, Thane (w) - 400601. (address) Comprised of Ground + 3rd floors owned / occupied by New Horizon Scholars School, Vasant Lawns, Subhash Nagar, Thane (w) - 400601. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 08/01/2024 (date of inspection) in the presence of Rahul Ashok Londhe Universal Fire & Safety Services Ltd (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X /XII) With effect from 09.02.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- | | | | |
|----------------------------------|-------|--------------------------------------|-------|
| 1. Wet Riser (4 Inch) | - Yes | 8. MCP/HOOTER | - Yes |
| 2. Hydrant Valve | - Yes | 9. Generator | - Yes |
| 3. Hose Reel With Shut-up Nozzle | - Yes | 10. Alarm Panal | - Yes |
| 4. Canvas Hose Pipe 15mtr | - Yes | 11. ABC Fire Extinguisher 4Kg Cap. | - Yes |
| 5. Booster Pump | - Yes | 12. CO2 Fire Extinguisher 3Kg Cap. | - Yes |
| 6. Electric Main Pump | - Yes | 13. CO2 Fire Extinguisher 4.5Kg Cap. | - Yes |
| 7. Lift | - Yes | 14. Underground Tank | Yes |

Issued on 09 /02/ 2024 (date of issue) at Thane (place) by

Signature with seal: -----

Name : Mr. Girish. M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane
 Municipal Fire Brigade, Thane.



To

New Horizon Scholars School
 Vasant Lawns, Subhash Nagar,
 Thane (w) - 400601.
 (Name & Address of the Institution)

ENDORSEMENT



The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)

Principal

New Horizon Scholars School
 Vasant Lawns, Thane

	<p style="text-align: center;">महाराष्ट्र शासन</p> <p style="text-align: center;">विद्युत निरीक्षक यांचे कार्यालय, निरीक्षण विभाग क्र.1, उद्योग ऊर्जा कामगार व खनिकर्म विभाग. प्लॉट क्र.45 अ, 10 वा रस्ता, वागळे इस्टेट, ठाणे (पश्चिम) 400 604</p>	
<p>e-mail : eithane1.nrg-mh@gov.in</p>		<p>☎ दूरध्वनि क्र . (022) 25821848</p>
<p>जा . क्र .विनिठा-१/ १२० /२०२४</p>		<p>दिनांक : १८/०९/२०२४</p>

प्रमाणपत्र

प्रमाणित करण्यात येते की न्यू हॉरीझॉन स्कॉलर्स स्कूल , वसंत लॉन्स ,सुभाष नगर ,डी .पी रोड ,ठाणे(पश्चिम), ठाणे -४००६०१ येथील विद्युत संच मांडणीचे निरीक्षण या कार्यालयामार्फत दिनांक १८.०९.२०२४ रोजी करण्यात आले असून सदर विद्युत संच मांडणी निरीक्षणाच्या वेळेस केंद्रीय विद्युत प्राधिकरण विनियम २०२३ (सुरक्षा व विद्युत पुरवठा) मधील तरतुदीनुसार सर्वसाधारणपणे योग्य व सुरक्षित आढळून आली आहे.


सदर प्रमाणपत्र खाली अटी व शर्तीच्या अधीन राहून देण्यात येत आहे.

१. विद्युत संचमांडणीमध्ये कोणताही बदल किंवा वाढ परस्पर करण्यात येऊ नये.
२. विद्युत संचमांडणी सुरक्षित व योग्य रित्या ठेवण्याची सर्वस्वी जबाबदारी ग्राहक/ मालक /भाडेकरू / परवाना धारक विद्युत ठेकेदार यांची राहिल.
३. सदरहू विद्युत संचमांडणीमध्ये योग्य क्षमतेचे अर्थ लिकेज प्रोटेक्टिव डिवाइस (ELPD/RCCB - 30mA) बसवावेत व ते कायम स्वरूपी कार्यरत राहतील याची खबरदारी घ्यावी. कोणत्याही परिस्थितीत ते बायपास करण्यात येऊ नये.
४. सदर ठिकाणी मीटर रूम मध्ये व्हेंटिलेशन करीता एक्झॉस्ट फॅन लावण्यात यावे.
५. प्रमाणपत्र दिनांक ३१.१२.२०२४ पर्यंत वैध राहिल.


Principal

New Horizon Scholars School
Vasant Lawns, Thane




(प्र. पां.पाटील)
सहाय्यक विद्युत निरीक्षक
निरीक्षण विभाग क्र.१, ठाणे